

Vales Point Power Station Monthly Environmental Data Summary



LICENCE NO	761	http://www.epa.nsw.gov.au/prpoeoapp/
LICENCE HOLDER	SUNSET POWER INTERNATIONAL PTY LTD	
REPORTING PERIOD	August 2019	
ADDRESS	VALES POINT ROAD, MANNERING PARK NSW	

POINT 1 Cooling water outlet at Wyee Bay, marked and shown as "VPOC" on the Plan (VX837351, 30.06.2015, DOC15/381265).											
Month	Pollutant	Unit of Measure	Sample/Measurement Frequency	Samples Collected & Analysed	Date Sampled	Lowest Sample Value	Mean of Samples	Highest Sample Value	EPL Limit	Exceedance (yes/no)	Comments
Aug-19	Chlorine (free residual)	milligrams per litre	Monthly	1	7/8/2019	0.09	0.09	0.09	0.2	No	
Aug-19	Temperature	degrees celsius	Continuous	100%	Aug-19	18.6	23.7	27.0	37.5	No	
Aug-19	Oil and Grease	Visible	Continuous	100%	Aug-19	NIL	NIL	NIL		No	No visible oil or grease detected during August 2019.

POINT 2 Discharge from the ash water recycle system to the cooling water outlet canal, marked and shown as "VPADB" on the Plan (VX837351, 30.06.2015, DOC15/381265).											
Month	Pollutant	Unit of Measure	Sample/Measurement Frequency	Samples Collected & Analysed	Date Sampled	Lowest Sample Value	Mean of Samples	Highest Sample Value	EPL Limit	Exceedance (yes/no)	Comments
Aug-19	Ammonia	milligrams per litre	Quarterly								
Aug-19	Cadmium	milligrams per litre	Quarterly								
Aug-19	Copper	milligrams per litre	Quarterly								
Aug-19	Lead	milligrams per litre	Quarterly								
Aug-19	Manganese	milligrams per litre	Quarterly								
Aug-19	Nitrate + nitrite (oxidised nitrogen)	milligrams per litre	Monthly	1	7/8/2019	<0.01	<0.01	<0.01			
Aug-19	Nitrogen (total)	milligrams per litre	Quarterly								
Aug-19	pH	pH	Monthly	1	7/8/2019	9.38	9.38	9.38	6.5 - 9.5	No	
Aug-19	Phosphorus (total)	milligrams per litre	Monthly	1	7/8/2019	0.13	0.13	0.13			
Aug-19	Reactive Phosphorus	milligrams per litre	Monthly	1	7/8/2019	<0.01	<0.01	<0.01			
Aug-19	Selenium	milligrams per litre	Quarterly								
Aug-19	Total Kjeldahl Nitrogen	milligrams per litre	Quarterly								
Aug-19	Total Suspended Solids	milligrams per litre	Fortnightly	2	Aug-19	6	7	8	50	No	
Aug-19	Zinc	milligrams per litre	Quarterly								

POINT 4 Seepage from ash dam rehabilitated area, marked and shown as "VPADS" on the Plan (VX837351, 30.06.2015, DOC15/381265).											
Month	Pollutant	Unit of Measure	Sample/Measurement Frequency	Samples Collected & Analysed	Date Sampled	Lowest Sample Value	Mean of Samples	Highest Sample Value	EPL Limit	Exceedance (yes/no)	Comments
Aug-19	Ammonia	milligrams per litre	Quarterly								
Aug-19	Cadmium	milligrams per litre	Quarterly								
Aug-19	Copper	milligrams per litre	Quarterly								
Aug-19	Lead	milligrams per litre	Quarterly								
Aug-19	Manganese	milligrams per litre	Quarterly								
Aug-19	Nitrate + nitrite (oxidised nitrogen)	milligrams per litre	Monthly	1	7/8/2019	0.25	0.25	0.25			
Aug-19	Nitrogen (total)	milligrams per litre	Quarterly								
Aug-19	pH	pH	Monthly	1	7/8/2019	7.99	7.99	7.99			
Aug-19	Phosphorus (total)	milligrams per litre	Monthly	1	7/8/2019	<0.05	<0.05	<0.05			
Aug-19	Selenium	milligrams per litre	Quarterly								
Aug-19	Total Kjeldahl Nitrogen	milligrams per litre	Quarterly								
Aug-19	Total Suspended Solids	milligrams per litre	Monthly	1	7/8/2019	2	2	2	50	No	
Aug-19	Zinc	milligrams per litre	Quarterly								

POINT 18 Overboarding of Ash Dam, marked and shown as "VPADD" on the Plan (VX837351, 30.06.2015, DOC15/381265).											
Month	Pollutant	Unit of Measure	Sample/Measurement Frequency	Samples Collected & Analysed	Date Sampled	Lowest Sample Value	Mean of Samples	Highest Sample Value	EPL Limit	Exceedance (yes/no)	Comments
Aug-19	Ammonia	milligrams per litre	Daily for discharge >2 hrs								
Aug-19	Cadmium	milligrams per litre	Daily for discharge >2 hrs								
Aug-19	Copper	milligrams per litre	Daily for discharge >2 hrs								
Aug-19	Lead	milligrams per litre	Daily for discharge >2 hrs								
Aug-19	Manganese	milligrams per litre	Daily for discharge >2 hrs								
Aug-19	Nitrate + nitrite (oxidised nitrogen)	milligrams per litre	Daily for discharge >2 hrs								
Aug-19	Nitrogen (total)	milligrams per litre	Daily for discharge >2 hrs								No discharge from EPA Point 18 during August 2019
Aug-19	pH	pH	Daily for discharge >2 hrs						6.5 - 9.0		
Aug-19	Phosphorus (total)	milligrams per litre	Daily for discharge >2 hrs								
Aug-19	Selenium	milligrams per litre	Daily for discharge >2 hrs								
Aug-19	Total Kjeldahl Nitrogen	milligrams per litre	Daily for discharge >2 hrs								
Aug-19	Total Suspended Solids	milligrams per litre	Daily for discharge >2 hrs						50		
Aug-19	Zinc	milligrams per litre	Daily for discharge >2 hrs								

POINT 19 Groundwater bore, marked and shown as "VPGM/D3" on the Plan (VX837351, 30.06.2015, DOC15/381265).											
Month	Pollutant	Unit of Measure	Sample/Measurement Frequency	Samples Collected & Analysed	Date Sampled	Lowest Sample Value	Mean of Samples	Highest Sample Value	EPL Limit	Exceedance (yes/no)	Comments
Aug-19	Arsenic	milligrams per litre	Quarterly								
Aug-19	Cadmium	milligrams per litre	Quarterly								
Aug-19	Calcium	milligrams per litre	Quarterly								
Aug-19	Chromium	milligrams per litre	Quarterly								
Aug-19	Copper	milligrams per litre	Quarterly								
Aug-19	Electrical conductivity	microsiemens per centimetre	Quarterly								
Aug-19	Iron	milligrams per litre	Quarterly								
Aug-19	Lead	milligrams per litre	Quarterly								
Aug-19	Magnesium	milligrams per litre	Quarterly								(next quarterly sample scheduled for October 2019)
Aug-19	Manganese	milligrams per litre	Quarterly								
Aug-19	Nickel	milligrams per litre	Quarterly								
Aug-19	pH	pH	Quarterly								
Aug-19	Potassium	milligrams per litre	Quarterly								
Aug-19	Selenium	milligrams per litre	Quarterly								
Aug-19	Sodium	milligrams per litre	Quarterly								
Aug-19	Standing Water Level	metres	Quarterly								
Aug-19	Zinc	milligrams per litre	Quarterly								

POINT 20 Groundwater bore, marked and shown as "VPGM/D5" on the Plan (VX837351, 30.06.2015, DOC15/381265).											
Month	Pollutant	Unit of Measure	Sample/Measurement Frequency	Samples Collected & Analysed	Date Sampled	Lowest Sample Value	Mean of Samples	Highest Sample Value	EPL Limit	Exceedance (yes/no)	Comments
Aug-19	Arsenic	milligrams per litre	Quarterly								
Aug-19	Cadmium	milligrams per litre	Quarterly								
Aug-19	Calcium	milligrams per litre	Quarterly								
Aug-19	Chromium	milligrams per litre	Quarterly								
Aug-19	Copper	milligrams per litre	Quarterly								
Aug-19	Electrical conductivity	microsiemens per centimetre	Quarterly								
Aug-19	Iron	milligrams per litre	Quarterly								
Aug-19	Lead	milligrams per litre	Quarterly								
Aug-19	Magnesium	milligrams per litre	Quarterly								(next quarterly sample scheduled for October 2019)
Aug-19	Manganese	milligrams per litre	Quarterly								
Aug-19	Nickel	milligrams per litre	Quarterly								
Aug-19	pH	pH	Quarterly								
Aug-19	Potassium	milligrams per litre	Quarterly								
Aug-19	Selenium	milligrams per litre	Quarterly								
Aug-19	Sodium	milligrams per litre	Quarterly								
Aug-19	Standing Water Level	metres	Quarterly								
Aug-19	Zinc	milligrams per litre	Quarterly								

POINT 21 Groundwater bore, marked and shown as "VPGM/D6" on the Plan (VX837351, 30.06.2015, DOC15/381265).											
Month	Pollutant	Unit of Measure	Sample/Measurement Frequency	Samples Collected & Analysed	Date Sampled	Lowest Sample Value	Mean of Samples	Highest Sample Value	EPL Limit	Exceedance (yes/no)	Comments
Aug-19	Arsenic	milligrams per litre	Quarterly								
Aug-19	Cadmium	milligrams per litre	Quarterly								
Aug-19	Calcium	milligrams per litre	Quarterly								
Aug-19	Chromium	milligrams per litre	Quarterly								
Aug-19	Copper	milligrams per litre	Quarterly								
Aug-19	Electrical conductivity	microsiemens per centimetre	Quarterly								
Aug-19	Iron	milligrams per litre	Quarterly								
Aug-19	Lead	milligrams per litre	Quarterly								(next quarterly sample scheduled for October 2019)
Aug-19	Magnesium	milligrams per litre	Quarterly								
Aug-19	Manganese	milligrams per litre	Quarterly								
Aug-19	Nickel	milligrams per litre	Quarterly								
Aug-19	pH	pH	Quarterly								
Aug-19	Potassium	milligrams per litre	Quarterly								
Aug-19	Selenium	milligrams per litre	Quarterly								
Aug-19	Sodium	milligrams per litre	Quarterly								
Aug-19	Standing Water Level	metres	Quarterly								
Aug-19	Zinc	milligrams per litre	Quarterly								

POINT 22 Groundwater bore, marked and shown as "VPGM/D8" on the Plan (VX837351, 30.06.2015, DOC15/381265).											
Month	Pollutant	Unit of Measure	Sample/Measurement Frequency	Samples Collected & Analysed	Date Sampled	Lowest Sample Value	Mean of Samples	Highest Sample Value	EPL Limit	Exceedance (yes/no)	Comments
Aug-19	Arsenic	milligrams per litre	Quarterly								
Aug-19	Cadmium	milligrams per litre	Quarterly								
Aug-19	Calcium	milligrams per litre	Quarterly								
Aug-19	Chromium	milligrams per litre	Quarterly								
Aug-19	Copper	milligrams per litre	Quarterly								
Aug-19	Electrical conductivity	microsiemens per centimetre	Quarterly								
Aug-19	Iron	milligrams per litre	Quarterly								
Aug-19	Lead	milligrams per litre	Quarterly								
Aug-19	Magnesium	milligrams per litre	Quarterly								(next quarterly sample scheduled for October 2019)
Aug-19	Manganese	milligrams per litre	Quarterly								
Aug-19	Nickel	milligrams per litre	Quarterly								
Aug-19	pH	pH	Quarterly								
Aug-19	Potassium	milligrams per litre	Quarterly								
Aug-19	Selenium	milligrams per litre	Quarterly								
Aug-19	Sodium	milligrams per litre	Quarterly								
Aug-19	Standing Water Level	metres	Quarterly								
Aug-19	Zinc	milligrams per litre	Quarterly								

POINT 23 Groundwater bore, marked and shown as "VPGM/D10" on the Plan (VX837351, 30.06.2015, DOC15/381265).											
Month	Pollutant	Unit of Measure	Sample/Measurement Frequency	Samples Collected & Analysed	Date Sampled	Lowest Sample Value	Mean of Samples	Highest Sample Value	EPL Limit	Exceedance (yes/no)	Comments
Aug-19	Arsenic	milligrams per litre	Quarterly								
Aug-19	Cadmium	milligrams per litre	Quarterly								
Aug-19	Calcium	milligrams per litre	Quarterly								
Aug-19	Chromium	milligrams per litre	Quarterly								
Aug-19	Copper	milligrams per litre	Quarterly								
Aug-19	Electrical conductivity	microsiemens per centimetre	Quarterly								
Aug-19	Iron	milligrams per litre	Quarterly								
Aug-19	Lead	milligrams per litre	Quarterly								
Aug-19	Magnesium	milligrams per litre	Quarterly								(next quarterly sample scheduled for October 2019)
Aug-19	Manganese	milligrams per litre	Quarterly								
Aug-19	Nickel	milligrams per litre	Quarterly								
Aug-19	pH	pH	Quarterly								
Aug-19	Potassium	milligrams per litre	Quarterly								
Aug-19	Selenium	milligrams per litre	Quarterly								
Aug-19	Sodium	milligrams per litre	Quarterly								
Aug-19	Standing Water Level	metres	Quarterly								
Aug-19	Zinc	milligrams per litre	Quarterly								

POINT 11 Stack serving Boiler Unit No. 5, marked and shown as "11" on the Plan (VX837351, 30.06.2015, DOC15/381265).											
Month	Pollutant	Unit of Measure	Sample/Measurement Frequency	Samples Collected & Analysed	Date Sampled	Lowest Sample Value	Mean of Samples	Highest Sample Value	EPL Limit	Exceedance (yes/no)	Comments
Aug-19	Cadmium	milligrams per cubic metre	Yearly						1	No	
Aug-19	Chlorine	milligrams per cubic metre	Yearly						200	No	
Aug-19	Copper	milligrams per cubic metre	Yearly								
Aug-19	Hydrogen chloride	milligrams per cubic metre	Yearly						100	No	
Aug-19	Mercury	milligrams per cubic metre	Yearly						1	No	
Aug-19	Moisture	percent	Yearly								
Aug-19	Molecular weight of stack gases	grams per gram mole	Yearly								
Aug-19	Nitrogen Oxides	milligrams per cubic metre	Continuous	100%	Aug-19	502	646	827	1500	No	
Aug-19	Sulfuric acid mist and sulfur trioxide (as SO3)	milligrams per cubic metre	Yearly						100	No	
Aug-19	Sulphur dioxide	parts per million	Continuous	100%	Aug-19	214	289	422	600	No	
Aug-19	Temperature	degrees Celsius	Yearly								
Aug-19	Total Fluoride	milligrams per cubic metre	Yearly						50	No	
Aug-19	Total Solid Particles	milligrams per cubic metre	Yearly						100	No	
Aug-19	Type 1 and Type 2 substances in aggregate	milligrams per cubic metre	Yearly						5	No	
Aug-19	Undifferentiated Particulates	milligrams per cubic metre	Continuous	100%	Aug-19	10.3	23.8	42.6			
Aug-19	Velocity	metres per second	Yearly								
Aug-19	Volatile organic compounds	parts per million	Yearly								
Aug-19	Volumetric flowrate	cubic metres per second	Yearly								

POINT 12 Stack serving Boiler Unit No. 6, marked and shown as "12" on the Plan (VX837351, 30.06.2015, DOC15/381265).

Month	Pollutant	Unit of Measure	Sample/Measurement Frequency	Samples Collected & Analysed	Date Sampled	Lowest Sample Value	Mean of Samples	Highest Sample Value	EPL Limit	Exceedance (yes/no)	Comments
Aug-19	Cadmium	milligrams per cubic metre	Yearly						1	No	
Aug-19	Chlorine	milligrams per cubic metre	Yearly						200	No	
Aug-19	Copper	milligrams per cubic metre	Yearly								
Aug-19	Hydrogen chloride	milligrams per cubic metre	Yearly						100	No	
Aug-19	Mercury	milligrams per cubic metre	Yearly						1	No	
Aug-19	Moisture	percent	Yearly								
Aug-19	Molecular weight of stack gases	grams per gram mole	Yearly								
Aug-19	Nitrogen Oxides	milligrams per cubic metre	Continuous	100%	Aug-19	573	779	927	1500	No	
Aug-19	Sulfuric acid mist and sulfur trioxide (as SO3)	milligrams per cubic metre	Yearly						100	No	
Aug-19	Sulphur dioxide	parts per million	Continuous	100%	Aug-19	168	291	407	600	No	
Aug-19	Temperature	degrees Celsius	Yearly								
Aug-19	Total Fluoride	milligrams per cubic metre	Yearly						50	No	
Aug-19	Total Solid Particles	milligrams per cubic metre	Yearly						100	No	
Aug-19	Type 1 and Type 2 substances in aggregate	milligrams per cubic metre	Yearly						5	No	
Aug-19	Undifferentiated Particulates	milligrams per cubic metre	Continuous	100%	Aug-19	6.1	8.0	9.7			
Aug-19	Velocity	metres per second	Yearly								
Aug-19	Volatile organic compounds	parts per million	Yearly								
Aug-19	Volumetric flowrate	cubic metres per second	Yearly								

GENERAL COMMENTS